



PLINTH AREA : 46.59 sq.m / 501.30 sq.ft

SCHEDULE OF JOINERY

SL. NO.	TYPE	SIZE		SILL	TOP	DESCRIPTION	REMARKS
		WIDTH	HEIGHT				
1	D	900	2100	-	2100	STEEL DOOR WITH 18GMS SHEET SHUTTER	SINGLE LEAF
2	D1	750	1200	-	-	STEEL DOOR WITH 18GMS SHEET SHUTTER	SINGLE LEAF
3	W	1200	1300	800	2100	STEEL WINDOW WITH 18GMS SHEET SHUTTER& 12MM SQ.MS.BARS	TWO LEAF
4	V	900	450	1650	2100	STEEL GLAZED VENTILATOR WITH 12MM SQ.MS.BAR	N-TYPE
5	J	900	450	1650	2100	R.C.C JOLLY	-
6	J1	600	1300	800	2100	R.C.C JOLLY	-

IMPORTANT NOTES:

- ECONOMICAL FOUNDATION MAY BE ADOPTED. DEPTH OF FOUNDATION SHOULD BE BASED ON THE SOIL CONDITION AT SITE.
- FLOORING SHOULD BE DONE USING CERAMIC TILES(FOR HALL ONLY).
- SILL SLAB(75mm THICK) SHOULD BE PROVIDED AT BOTTOM OF ALL WINDOW OPENINGS WITH 250 mm EXTENSION ON EITHER SIDE.
- PLINTH PROTECTION PLATFORM(750mm WIDTH) SHOULD BE PROVIDED AROUND THE BUILDING
- SLIGHT SLOPE SHOULD BE GIVEN FOR ROOF SLAB
- WEATHERING COURSE SHOULD BE PROVIDED WITH REQUIRED SLOPE TO DRAIN RAIN WATER.
- RWH STRUCTURE SHOULD BE CONSTRUCTED AWAY FROM SEPTIC TANK(IF ANY) AND IT CAN BE LINKED TO A NEAR BY WATER SOURCE.
- 110 mm OD PVC PIPES MAY BE USED FOR RAINWATER DOWNFALL PIPES.
- WASHING AREA SHOULD BE 100mm LOWER THAN FLOOR LEVEL.
- CARTOONS SHOULD BE DRAWN INSIDE THE HALL AND TOILET ONLY.
- PVC TANK OF 500 LITRES CAPACITY SHOULD BE PROVIDED.
- CONTINUOUS UNTEL SHOULD BE PROVIDED.

DRAWING NO:1-J3/SERD/Dt.03.09.11

DIRECTORATE OF RURAL DEVELOPMENT AND PANCHAYAT RAJ

SCALE 1:100 DATE: ALL DIMENSION ARE IN mm.

AE: [Signature] EE: [Signature] JOB NO:3 DRAWING NO:1

TYPE DESIGN FOR NOON MEAL CENTRE/ANGANWADI

PLAN, ELEVATION AND SECTION