



**NOTE**

1. All steel reinforcement will be checked by the structural engineer
2. Grade of concrete M 20
3. Grade of steel Fe 415 conforming to IS 1786 - 1985
4. Cement content should not be less than 400 kg/cum
5. Cube strength of the concrete has to be checked for 7 days & 28 days strength periodically
6. Curing for the concrete should go for 21 days
7. Water to be used for curing should be good quality potable water
8. Approved water proofing compound to be used for water proof
9. Clear cover to main reinforcement
  - a) top = 25 mm
  - b) bottom = 40 mm
  - c) beam = 25 mm
  - d) slab = 15 mm