



AREA=188.84 Sqft

SCHEDULE OF JOINERIES

D	Door	0.90m x 2.10m
D1	Door 1	0.75m x 2.10m
J	Jolly	0.60m x 0.45m

IMPORTANT NOTES

1. THE FLOORING SHOULD BE OF ANTI SKID NATURE TO AVOID SLIPPING
2. THE FLOORING MATERIAL SHOULD BE A CONTINUOUS SURFACE WITH MINIMUM SEALED JOINTS TO PREVENT ACCUMULATION OF DIRT.
3. SHARP CORNERS HAVE TO BE AVOIDED. OUT SIDE CORNERS HAVE TO BE CHAFERED OR ROUNDED.
4. DOOR LATCH HEIGHT SHOULD NOT BE MORE THAN 730 MM
5. HOOKS SHOULD BE FIXED AT THE HEIGHT NOT MORE THAN 1575MM
6. A SMALL NICHE AT 571MM TO 600MM HEIGHT FROM THE FLOOR NEEDS TO BE PROVIDED TO PLACE FRESH SANITARY NAPKINS.
7. THE HEIGHT OF HAND WASH SHOULD NOT BE MORE THAN 780MM AND THE TAPS SHOULD BE FIXED AT 600MM INTERVAL
8. PASSAGE ROOF SHOULD BE UV COATED POLYCARBONITE SHEET OF 12MM THICK
9. TOILET BASEMENT, SEPTIC TANK, LEACH PITS OR SOAK PITS MUST BE PROVIDED AS PER THE SOIL CONDITION OF THE PROPOSED SITE.
10. THE SLOPE INSIDE THE TOILET UNIT SHOULD BE TOWARDS THE TOILET SEAT TO DRAIN OFF WATER

**TYPE-4
MINI COMMUNITY SANITARY COMPLEX FOR GIRLS (MIDDLE)**